

Filing Requested By:
City of Turlock
Planning Division
156 S. Broadway, Suite 120
Turlock, CA 95380-5456

When Filed Mail To:
Same as above

FILED

20 APR 23 PM 2:31

STANISLAUS CO. CLERK-RECORDER

BY Phaivann Prum
DEPUTY

SPACE ABOVE THIS LINE RESERVED FOR CLERK'S USE ONLY

TITLE OF DOCUMENT

Notice of Determination
MDP 2019-18 City of Turlock Well 38

See attached document

Date removed from posting 5/27/2020

Notice of Determination

Appendix D

To:

Office of Planning and Research
U.S. Mail: P.O. Box 3044 Sacramento, CA 95812-3044
Street Address: 1400 Tenth St., Rm 113 Sacramento, CA 95814

County Clerk
County of: Stanislaus
Address: 1021 I Street Modesto Ca 95354

From:

Public Agency: City of Turlock
Address: 156 S Broadway Turlock Ca 95380
Contact: Fallon Martin, Staff Services Analyst
Phone: (209) 668-5590

Lead Agency (if different from above):
Address:
Contact:
Phone:

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

State Clearinghouse Number (if submitted to State Clearinghouse): 2020029025

Project Title: Well No. 38 Arsenic Treatment

Project Applicant: City of Turlock

Project Location (include county): Stanislaus County, Turlock, APN 087-026-005

Project Description:

The City will install an iron-assisted coagulation filtration plant to treat for arsenic at Well 38. System includes chemical pretreatment, pressure vessels with filter media, equalization tank, backup generator, and chemical enclosure on site. A one-million-gallon storage tank will be installed in the future. Granular activated carbon vessels will be added to treat 1,2,3-Trichloropropane if needed in future.

This is to advise that the City of Turlock has approved the above (Lead Agency or Responsible Agency)

described project on April 15, 2020 and has made the following determinations regarding the above described project.

- 1. The project will not have a significant effect on the environment.
2. An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA. A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
3. Mitigation measures were made a condition of the approval of the project.
4. A mitigation reporting or monitoring plan was adopted for this project.
5. A statement of Overriding Considerations was adopted for this project.
6. Findings were made pursuant to the provisions of CEQA.

This is to certify that the final EIR with comments and responses and record of project approval, or the negative Declaration, is available to the General Public at:

City of Turlock, 156 S Broadway, Turlock Ca 95380

Signature (Public Agency): [Handwritten Signature] Title: Interim City Manager

Date: 4/14/2020 Date Received for filing at OPR: