

POOL / SPA DAILY MAINTENANCE LOG

California Code of Regulations, Title 22, Section 65523:

- A. The operator of each pool open for use shall keep a daily record of information regarding operation, including reading of disinfectant (e.g., chlorine) residual, pH, and maintenance procedures such as cleaning of filters and quantity of chemicals used.
- B. If cyanuric acid (stabilizer) is added to the pool, the concentration shall be measured a minimum of once per month and records shall be kept of the results.

Facility:			
Month:	Year:	Capacity (gal):	Required flow rate (gpm):

Date	Morning		Afternoon		Note
	pH	Chlorine	pH	Chlorine	
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

HOLE PUNCH HERE

Monthly cyanuric acid test – Testing date:	Result:
--	---------

Reminders

Free Chlorine Residual:	pH:	Cyanuric acid:	Maximum water
2.0ppm minimum for pool with stabilizer	Operational range: 7.2 to 7.8	Less than 100ppm	temperature:
3.0ppm minimum for spa with stabilizer	Ideal 7.4 to 7.6	Ideal 30 to 50ppm	104°F
1.0ppm minimum without stabilizer			

Questions? Please call Stanislaus County Dept. of Environmental Resources at (209) 525-6700