



STANISLAUS COUNTY
 DEPARTMENT OF ENVIRONMENTAL RESOURCES
 3800 CORNUCOPIA WAY, SUITE C, MODESTO, CA 95358
 209/525-6700 FAX 209/525-6774

Permit No. _____
 Permit Exp. _____
 Fee Paid _____

APPLICATION AND PERMIT TO TEMPORARY CLOSE UNDERGROUND STORAGE TANK

Facility Name _____ Facility Address _____

Owner _____ Operator _____ Date _____

I propose to close _____ underground storage tank (s) according to specifications in CCR Title 23, Article 7, Section 2671. The temporary closure will be for a maximum period of 12 months from the date of temporary closure submittal. The following steps shall be confirmed by this department prior to tanks being put into temporary closure.

- 1) All residual liquids, solids or sludges shall be removed and handled in accordance with the applicable provisions of Chapters 6.5 and 6.7 of the Health and Safety Code.
- 2) Name of Company triple rinsing tanks _____
 date of triple rinse _____. The rinsate will be removed by _____;
 a licensed oil recycling company (or licensed hazardous waste hauler). Tank shall be cleaned by a high temperature, pressure washer with a non-hazardous, biodegradable detergent.
- 3) All tanks under temporary closure shall be inerted, as often as necessary, to levels that will preclude an explosion or to lower levels as required by this department.
- 4) Except for required venting, all fill and access locations and piping shall be sealed using locking caps or concrete plugs.
- 5) Power service shall be disconnected from all pumps associated with the underground storage tank, unless the power services some other equipment not being closed, such as the impressed current cathodic protection system or tank monitoring system.
- 6) Single walled tanks shall be precision tested. All tanks must continue to comply with repair and record keeping requirements, release reporting and investigation requirements, and release response and corrective action requirements specified in CCR Title 23, division 3, Chapter 16 and Chapter 6.7 of the Health and Safety Code.
- 7) NO TANK WILL BE CONSIDERED FOR CLOSURE WITHOUT CURRENT MONITOR CERTIFICATIONS, PRECISIONS TESTING (if required), INSURANCE FORMS, UST FACILITY AND UST TANK FORMS.
- 8) The underground storage tank shall be inspected by the owner or operator at least once every three months to verify the temporary closure measures are still in place. The inspection shall include but is not limited to the following and will be inspected by _____;
 - a) Visual inspection of all locked caps and concrete plugs.
 - b) If locking caps are used, at least one shall be removed to determine if any liquids or any other substance has been added to the underground storage tank.

This is only an application. When this department has confirmed that the temporary closure steps are in place you will be sent your approved temporary closure.

OWNERS SIGNATURE _____ DATE _____

PRINT NAME _____ 24 HOUR PHONE NUMBER _____

DEPARTMENT USE	
_____	Tanks inerted
_____	Tank access piping locked
_____	Electricity disconnected
_____	Inspectors initials